San Francisco Department of Public Health

Self-Inspection Compliance Checklist for Auto Repair Shops

An alternate self-inspection checklist may be used provided that all items outlined below are included.

| Instructions: Conduct self-inspections on a quarterly basis. Check (✓) "Yes" if | | Date of Quarterly Self-Inspection | | | | |
|--|-----------------------------------|-----------------------------------|------------|------------|----------|----------|
| facility meets requirements. ✓ "No" and enter a correction date when facility will correct deficiency. Otherwise, ✓ Not Applicable ("NA"). | | Y N Date | Y N Date | Y N Date | Y N Date | |
| Recordkeeping | ripplicable (1471). | NA | | | | |
| | | | | | | |
| 1. The business plan is current and main | | | | | | |
| HMUPA fees were paid and valid cer posted in an area that is accessible to | | | | | | |
| 3. Facility map(s) is current and maintain | ned on site. | | | | | |
| 4. Hazardous materials/waste inventory | | | | | | |
| 5. All employees have received their and training class roster. | nual training and have signed the | | - - | | | |
| 6. Material Safety Data Sheets (MSDS) available and accessible to all employ | | | | | | |
| 7. Required receipts, manifest, and/or log | gs are maintained on site (e.g., | | | | | |
| hazardous waste disposal manifest or | 1 | | | | | |
| back-up diesel generator usage logs, h self-inspection records, records of spi | | | | | | |
| notifications [UARR], underground st | | | | | | |
| logs, UST leak detection records, etc. | | | | | | |
| 8. Hazardous waste generators: EPA ID# "active". | has been obtained and is | | | | | |
| 9. Emergency Response plan kept on site plan is posted. | e; hazardous waste contingency | | | | | |
| | | | | | 0 0 | |
| 10. Other | | | | шш | | |
| <u>Housekeeping</u> | | | | | | |
| 1. Work, storage, mixing, etc. areas are l | kept clean and orderly. | | 0 0 | - - | 0 0 | 0 0 |
| 2. Eyewashes and emergency showers ar | <u> </u> | | | | | |
| 3. In storage areas serving only employe minimum. | es, aisles meet 24-inch clearance | | | | | |
| 4. Spill equipment kits are clearly labele for use in a ready condition. | d, visibly located and available | | - - | | | |
| 5. Other | | | | | | |
| Hazardous Material/Waste Storage Area(s | <u>)</u> | | | | | |
| _ | | | | | | |
| Incompatible hazardous materials/was segregated to prevent accidental mixin flammables and oxidizers; flammables | ng (e.g., acids from bases, | | - - | | <u> </u> | <u> </u> |
| 2. No hazardous waste generated off-site | e stored on-site. | | | | | |
| Hazard ID signs posted and used corrections | | | | | | |
| 4. Hazardous waste determination has be | - | | | | | |
| 5. Satellite waste accumulation areas are | properly managed. | | | | | |
| 6. Universal waste is stored in a designation | | | | | | |
| 7. Other | | | | | 0 0 | 0 0 |

San Francisco Department of Public Health

Self-Inspection Compliance Checklist for Auto Repair Shops

An alternate self-inspection checklist may be used provided that all items outlined below are included.

| Hazardous Material/Waste Container Management | NA | Y N Date | Y N Date | Y N Date | Y N Date |
|---|-------|----------|------------|------------|------------|
| 1. Hazardous material/waste containers, including batteries and oil filters, are properly labeled. Hazardous waste labels include the following: the title "Hazardous Waste", "Used Oil", etc.; generator information; composition and physical state; hazard property; and accumulation start date. | | | | | |
| 2. Hazardous waste stored for <90 days or <180 days, not exceeding quantity limits. (Recyclable waste may be stored up to 1 year.) | | | | | |
| 3. Hazardous materials/wastes are stored in appropriate, compatible, and approved containers, in good condition | | | | | |
| If required, hazardous material/waste containers are provided with adequate secondary containment. | | | | | |
| 5. Used oil filters are properly managed, including labeling containers "Drained Used Oil Filters". | | | | | |
| 6. Empty containers labeled "EMPTY" or similar wording, marked wi date emptied. | th | | | | |
| 7. Empty containers are properly managed within 1 year. | | | | | |
| 8. All hazardous material/waste containers are closed when not in use. | | | | | |
| 9. Universal waste is stored in closed, structurally sound containers, | | | | | |
| 10. Universal waste containers are marked with "Universal Waste" and waste type (e.g. lamps, batteries, electronic devices). Accumulation start date is documented for each container. | | | | | |
| 11. Broken and leaking Universal Waste items are placed in sealed plastic bags before being placed in appropriate container. | | | | - - | - - |
| 12. Other | | | | | 0 0 |
| <u>Underground Storage Tank(s)</u> | | | | | |
| 1. Required records and logs are maintained on site (e.g. annual calibration/maintenance checks, alarm history logs, cathodic protection system maintenance, monthly automatic tank gauging or statistical inventory reports, etc.). | 0 | | | | |
| 2. Spill and secondary containments are free from liquids and debris. | | | | | |
| 3. Sensors are positioned at the lowest point for earliest possible detection of liquid. | | | | | |
| 4. Local agency is notified 48 hours prior to conducting any installatio repair, replacement, calibration, or certification of monitoring equipment. | n, | | | | |
| 5. Monitoring certification conducted annually. | | | | | |
| 6. Designated operator is certified, HMUPA notification current. | | | | | |
| 7. SB 989 tests conducted within three years. | | | | | |
| 8. Tank system repairs conducted as warranted. | | | | | |
| 9. Other | | | | | |
| Aboveground Petroleum Storage Tank(s) | | | | | |
| If storing over 1320 gallons in 55 gal drum or larger, of any petroleu product including waste oil: register through APSA (Aboveground Petroleum Storage Act). The Proof of the P | | | | | |
| 2. Tank Facility Statement or Business Plan was submitted. | ID C | | | | |
| 3. A SPCC (spill prevention control and countermeasure) Plan v prepared and implemented. | vas 🗆 | | - - | - - | |

San Francisco Department of Public Health

Self-Inspection Compliance Checklist for Auto Repair Shops

An alternate self-inspection checklist may be used provided that all items outlined below are included.

| 4. | The SPCC Plan is available onsite. | | | |
|-----|---|-----|--|--|
| 5. | The 5-year Plan review and evaluation was conducted and documented. | 0 0 | | |
| 6. | Discharges were reported to HMUPA and Cal EMA (OES). | | | |
| 7. | Tanks are structurally maintained to stop/prevent leaking. | | | |
| 8. | Permanently closed tanks are labeled as closed/empty and with the date permanently closed. | | | |
| 9. | Master flow and secondary containment valve(s) are closed and secured when in non-operating or non-standby status | 0 0 | | |
| 10. | Oil accumulated in the secondary containment is removed. | | | |
| 11. | Other | 0 0 | | |

| Signature of Person Conducting Quarterly Inspection | Phone Number | |
|---|--------------|--|